

**ADDENDUM 2
TO CONTRACT DOCUMENTS FOR THE**

PILLAR POINT FISHING PIER REHABILITATION


**SAN MATEO COUNTY HARBOR DISTRICT
PILLAR POINT MARINA, CALIFORNIA**


The following responses to bidder questions are provided:

- The rock for breakwater repairs is nominally 75-lb rock that is generally considered Facing Class rock. The gradation is provided in the Technical Specifications Section 321110 "Rock Slope Protection" paragraph 2.1.A. "Riprap."
- The construction cost for the project is estimated to range from \$275,000 to \$450,000.

No changes to the contract documents have been made as part of this Addendum.

Prepared by:
Moffatt & Nichol


Name: Neil Nichols, PE June 26, 2019
Date


John Moren, Director of Operations June 26, 2019
San Mateo County Harbor District Date